

## Datasheet Breathing filter 85 ABEKSt

Designation:	Respiratory protection screw filter ABEK2-P2 R D Combination filter to DIN EN 14387 Filter type/class A2 B2 E2 K2 - P2 R D as part of a respiratory protective device to DIN EN 133 - Filter device	
Description:	Cylindrical housing with round thread connection according to DIN EN 148-1 (external thread Rd 40 x 1/7)	
Article-Number:	924601	
Application:	In conjunction with breathing connection - full face masks (DIN EN 136) with round thread connection - for protection against organic gases and vapors with boiling point above 65°C, against inorganic gases and vapors e.g. chlorine, hydrogen sulfide (hydrogen sulfide), hydrogencyanide (hydrogen cyanide, hydrogen cyanide) against sulfur dioxide, hydrogen chloride (hydrogen chloride), against ammonia - not against carbon monoxide – and against particles R = Reusable - reusable against particles D = particularly resistant to clogging by dust (storage test with dolomite dust according to EN 143)	
Standards:	DIN EN 133 DIN EN 148-1  DIN EN 14387	Respiratory protective devices - Classification Respiratory protective devices - Threads for breathing connections - Round thread connection Respiratory protective devices - Gas filters and combination filters
Identification colors:	brown - grey - yellow - green - white (adhesive label)	
Materials:	Housing, perforated disks Filter medium Non-woven discs Sealing foil	Aluminum alloy Activated carbon and glass/cellulose fiber Polypropylene Polypropylene
Dimensions:	Diameter approx. 108 mm Height approx. 104 mm	
Weight:	approx. 365 grams	
Inhalation resistance:	< 2.6 mbar at 30 l/min constant air flow < 9.8 mbar at 95 l/min constant airflow	
Filter flow rate:	Sodium chloride test at 95 l/min: < 6 % Kerosene oil test at 95 l/min: < 6 %	
Storability:	6 years - from date of manufacture (protected from cold, heat and moisture)	
Handling:	Only open the filter immediately before use and screw firmly into the connector of the mask.	



Revision 11.2023 – Errors and omissions excepted. All data are non-binding guide values.

**BartelsRieger Atemschutztechnik GmbH**

Richard-Byrd-Straße 23 | 50829 Cologne | Phone +49 (0)221 59777-0 | mail@bartels-rieger.de | www.bartels-rieger.de  
Ust.-IdNr. DE 815603312 | St.-Nr. 217/5811/1510 | Reg.-Gericht Köln | HRB 54098 | Managing Director: Tobias Rutt

## Datasheet Breathing filter 85 ABEKSt

**Main application:** A - Organic gases and vapors (boiling point > 65°C) | B - Inorganic gases and vapors | E - Acid gases | K - Ammonia and organic ammonia derivatives | P - Particles.

**Service life:** The service life of combination filters depends on several factors such as concentration of harmful gases, ambient temperature, humidity, working conditions, posture, etc. and therefore cannot be determined in advance.  
Opened filters must be replaced after 6 months at the latest.

**Application limits:** according to technical rules for hazardous substances TRGS 900 "Occupational exposure limits"

with full face mask (particle filter):	15 times the occupational exposure limit value
with full face mask (gas filter):	400 times the occupational exposure limit value

Maximum permissible  
Gas concentration: of gas filter class 2 (A2, B2, E2, K2) = 5,000 ml/m<sup>3</sup>

**Instructions for use:** The use of breathing filters requires a basic knowledge of the function and handling of respiratory protective devices. Information on this can be found in the trade association regulations and rules, in particular in DGUV Rule 112-190.

The use of breathing apparatus generally means additional stress for the person wearing the breathing apparatus.  
Most respiratory protective devices require occupational health screening in accordance with the "Ordinance on Occupational Health Care" (ArbMedVV).  
**Damaged filters must not be used.**

In ATEX areas, these respiratory protection filters can be used in potentially explosive atmospheres in zones 1, 21, 2 and 22 if the following requirements are observed:

- The respiratory protection filters must be earthed via a dissipative mask and via the earthing of the wearer with a leakage resistance <108 Ω.
- The respiratory protection filters must not be used in areas where highly charge-generating processes are to be expected.
- In the presence of an explosive atmosphere, the respiratory protection filters may only be worn on the face mask and not on the belt.
- The permissible ambient temperature must not exceed a value of 70 °C, assuming a temperature increase of 10 K at the parts in contact with an explosive atmosphere during normal operation and also in the event of a fault (zone 1 or 21) or during normal operation (zone 2 or 22) due to the activated carbon filter

Revision 11.2023 – Errors and omissions excepted. All data are non-binding guide values.

**BartelsRieger Atemschutztechnik GmbH**

Richard-Byrd-Straße 23 | 50829 Cologne | Phone +49 (0)221 59777-0 | mail@bartels-rieger.de | www.bartels-rieger.de  
Ust.-IdNr. DE 815603312 | St.-Nr. 217/5811/1510 | Reg.-Gericht Köln | HRB 54098 | Managing Director: Tobias Rutt

## Datasheet Breathing filter 85 ABEKSt

Rules / regulations: Regulation (EU) 2016/425 on personal protective equipment  
PPE Usage Ordinance (PSA-BV)  
Ordinance on Occupational Health Care (ArbMedVV)  
BGV A1 Employer's Liability Insurance Association Regulation for Safety and Health at Work - Accident Prevention Regulation - Principles of Prevention

DGUV Rule 112-190 Employer's liability insurance association rules for safety and health at work - "Use of respiratory protective devices"

Hazardous Substances Ordinance (GefStoffV) with associated Technical Rules for Hazardous Substances (TRGS), in particular TRGS 402  
"Determination and assessment of hazards during activities involving hazardous substances: Inhalative exposure" and other technical rules for hazardous substances.

Order details:	Article number	Description
	924601	Combination filter 85 ABEKSt
	111200	Full face mask BRK 820
	111201	Full face mask BRK 820 V
	111208	Full face mask BRK 820 G
	111400	Full face mask TR 2002 CL3
	111704	Wall container for full face mask including one filter
	111705	Wall container for two full face masks including two filters
	111703	Carrying box B78 for one full face mask and one filter

Revision 11.2023 – Errors and omissions excepted. All data are non-binding guide values.

**BartelsRieger Atemschutztechnik GmbH**

Richard-Byrd-Straße 23 | 50829 Cologne | Phone +49 (0)221 59777-0 | [mail@bartels-rieger.de](mailto:mail@bartels-rieger.de) | [www.bartels-rieger.de](http://www.bartels-rieger.de)  
Ust.-IdNr. DE 815603312 | St.-Nr. 217/5811/1510 | Reg.-Gericht Köln | HRB 54098 | Managing Director: Tobias Rutt